

Recycled Water Onsite Supervisor Do's and Don'ts

- Install and maintain signs at all points of entry (pedestrian and vehicular);
- Install and maintain labels and tags on recycled and potable water systems;
- Operate irrigation system:
 - Between 9 p.m. 6 a.m. if automatically controlled (unless other restrictions apply).
 - At other times if manually controlled and supervised (someone present) to make sure the recycled water doesn't come in contact with the public;
 - At any time if use site is restricted to the public- use quick couplers instead of hose bibs;
 - Efficiently to conserve water and reduce run-off;
- © Contact water provider if any water system (recycled or potable) modifications are anticipated;
- Immediately contact water provider if any one of the following has occurred:
 - A recycled water line break, spill, or off –site discharge;
 - A violation of water recycling requirements;
 - A cross-connection between the recycled and potable water systems;
- Educate/train site workers on safe use and restrictions of recycled water;
- Keep records and as-built drawings up-to-date and accessible;
- Assist and cooperate during periodic visual inspections;
- Assist and cooperate during periodic cross-connection testing
- Wash hands with soap and clean water after exposure to recycled water.



Recycled Water Onsite Supervisor Do's and Don'ts

- Don't drink the recycled water;
- Don't use recycled water to wash hands or any other part of the body;
- Don't remove the water identification signs, tags or labels;
- Don't cross-connect two dissimilar water systems (recycled to potable);
- Pon't allow recycled water to pond or puddle;
- Pon't allow recycled water to contact drinking fountains or eating areas;
- Pon't allow recycled water to runoff the use site property by either overspray or over watering;
- Pon't use recycled water on an unapproved site;
- Pon't put hose bibs on recycled water systems (unless public is restricted);
- Don't use the same equipment on both recycled water and domestic water systems (for example, quick couplers, tools, etc.);
- Don't modify any water system without prior approval of water provider and/or Health Department.