

NOTES:

1. All ornamental street lighting cable systems shall be underground, rather than overhead.
2. Location of street light standards to be approved by City Building Maintenance (805) 564-5415, prior to installation.
3. Residential light standards shall be spaced on lot lines not more than two hundred-fifty (250) feet apart approximately.
4. Where commercial or industrial lot frontages are involved, light standards shall be spaced one hundred (100) feet apart.
5. All other features of street lighting systems shall meet the requirements of the Public Works Department which shall be established to achieve safety, maximum life, low maintenance cost, adequate illumination and structural soundness.
6. All pull boxes shall be set at the back of the curb. Roadway pull boxes are for replacement purposes only.
7. All pull boxes shall be set in accordance with N.E.C. and CALTRANS Standards.
8. When the distance between street lights is greater than 100 feet, a pull box must be set every 100 feet for pulling wire.

REVISED	DATE	APPROVED	CITY OF SANTA BARBARA - PUBLIC WORKS DEPARTMENT	STANDARD DETAIL
		<i>Anthony M. Wood</i>	LIGHT STANDARD SPACING - NOTES	3-005.0-06
		PUBLIC WORKS DIRECTOR		
			DATE	
			1/31/02	