



City of Santa Barbara

Fire Department

www.SantaBarbaraCA.gov

Administration

Tel: 805.965.5254

Fax: 805.564.5730

**Fire Prevention/
Public Education**

Tel: 805.564.5702

Fax: 805.564.5715

121 W. Carrillo Street

Santa Barbara, CA

93101

April 4, 2007

Suzanne Elledge Planning & Permitting Services
Trish Allen, Associate Planner
800 Santa Barbara Street
Santa Barbara, CA 93101

Subject: Alternate method of Compliance Request for Commercial Access
930 Miramonte Drive (MST2004-00743)

Dear Ms Allen

We have reviewed your request for a modification to the Fire Department access requirements for the above project. Based on the information provided in your request dated March 27, 2007 we hereby approve your requested based on the following.

1. All proposed measures of the letter of requested dated March 27, 2007 shall apply.
2. The Fuel Modification Plan shall be approved prior to Building permit.
3. The extension of the access to the East of the building shall be a minimum of 20 feet in width with a vertical clearance of 13 feet 6 inches.
4. The shelter in place and disaster evacuation plan shall be approved prior to Occupancy.
5. The non-combustible construction classification as identified within the request shall be a UBC approved construction type. The type of construction shall continue throughout any new construction and meet the provisions under the Building Code.

You will need to imprint a copy of this letter to your plans when submitting for plan review. If you have any further questions, feel free to call me at 564-5701.

Sincerely,

Russ Cole, Fire Marshal

EXHIBIT J