

Santa Barbara City Fire Department - Standard Operating Procedures Training Operations	Code: T-II-9
2 1/2" Reverse Lay	
Chpt: II Hose Lays	Revised: 3/29/13 Pages: 1

Objective: To lay a single supply line from another engine to the hydrant.

<u>STEP #</u>	<u>CAPTAIN</u>	<u>ENGINEER</u>	<u>FIREFIGHTER</u>
1	Gives order to Engineer and Firefighter.	Receives order from Captain.	Receives order from Captain.
2		Stop Engine within 5 feet past suction connection of pumping engine; watch for signal to proceed.	Take line from right hose bed and connect double male from rear of truck; pull enough hose to reach engine suction.
3		Go to hydrant when ordered; spot hydrant for pumping and follow proper procedures for pumping from hydrant. (See T-II-3 General instructions, Engineer)	Hold anchor until Engine is 100' away or stops; connect line to inlet and report to Captain.