



City of Santa Barbara- Public Works Department

SEWER LATERAL INSPECTION PROGRAM

May 13, 2017

SUBJECT: NOTIFICATION OF OUTSTANDING REQUIREMENT(S)

STREET:

Lateral #:

APN #:

PRE CASE #:

WO Number WW-

Dear Property Owner or Representative:

Thank you for submitting the videotaped inspection of your sewer lateral(s) and the supporting documentation. Our staff has received these items and identified problems with your lateral. It is the responsibility of the property owner to maintain the sewer lateral(s) in proper working condition at all times (SBMC, Section 14.44.160.1.1).

Per review of the Inspection Form and/or videotape, the following is required:

- * Replace lower lateral. **From 48' to 54' to correct various broken joints.**
- * Replace wye connection at the sewer main.
- * Your property requires a backwater valve.
- * Submit documentation (i.e. Plumbers Invoice) that required cleaning or repair(s) are completed.

The above listed items need to be submitted to us by no later than 06/13/2017.

Please submit all documentation to: Sewer Lateral Inspection Program Coordinator, 630 Garden Street, Santa Barbara, CA 93101.

Please note that most repairs will require a permit and that all repairs made must be permitted by the City prior to starting the repair work. Permits can be obtained at the Public Works and/or Building counters, located at 630 Garden Street, between the hours of 8:30a.m. and 4:30p.m., Monday through Friday (closed every other Friday). You may call (805) 564-5485 to listen to a recorded message indicating whether the office is open on a particular Friday.

Thank you in advance for your cooperation to resolve this matter. Clean, well maintained sewer lines prevent spills of sewage to the environment.

If you wish to discuss this issue or have any further questions, please contact me (805) 568-1032.

Sincerely,

A handwritten signature in black ink, appearing to read "Dale Escobar", with a long horizontal flourish extending to the right.

Dale Escobar
Sewer Lateral Inspection Coordinator

cc: Geoff Lancaster, Senior Building Inspector
Street File